

Asansol Municipal Corporation

Borough-II, Raniganj


Md. Mozammil Hussain
Chairman

N.S.B. Road, P. O:Raniganj
Dist.: PaschimBardhaman.
Pin: 713347

Phone : (0341)244-4825/244- 7485
E-mail: amcraniganj@gmail.com

Ref. No.: AMC-Rnj/N.O.C/25-26/ 372

Date : 15.09.2025.



TO WHOM IT MAY CONCERN

It is certified that an inspection to Raniganj Lions J.D.M. Chanani DAV Public School, Lions Eye Hospijjal Road, Post & P.S. Raniganj, Dist. Paschim Bardhaman(W.B) was conducted by the Sanitary Department of Borough-II, Asansol Municipal Corporation and found that Raniganj Lions J.D.M. Chanani DAV Public School has proper hygienic sanitation condition in the School Building & the Campus.

Chairman,
Borough-II, Raniganj
Asansol Municipal Corporation
Chairman, Borough - II
Asansol Municipal Corporation
Raniganj Office

Principal
Raniganj Lions J.D.M. Chanani
D.A.V. Public School

Manager
RLJDMC D.A.V Public School
RANIGANJ, WEST BENGAL

PASCHIM BARDHAMAN WATER TESTING DISTRICT LABORATORY

ISMILE (WEST), VIVEKANANDA PALLY, ASANSOL - 713301

Phone & Fax - 0341 2284210, E-mail: ee_rcfa_d1@wbphed.gov.in,

Asansol PHE Office (R.C.F.A.Div-1) Laboratory, E-mail: rcfalabasansol@gmail.com

Paschim Bardhaman,




Results of Physical Chemical & Bacteriological analysis of water sample

Water sample of ----- RANIGANJ LIONS J.D.M CHANANI
DAV PUBLIC SCHOOL, RANIGANJ, PASCHIM BARDHAMAN.
Sample received from----- WATER SAMPLE OF PURIFIER
Sample Collected by----- CONCERN AUTHORITY
Sample Submitted by----- CONCERN AUTHORITY
Sample received on ----- 25/08/2025
Test Completion Date -----26/08/2025
Sample reference no ----- 38/1330/LAB-2025 /RCD-1
GRN NO:----- 192025260223702348
MEMO NO----- DAV RNJ/2025-26/530


Sample Tested as Received

Parameters	Observed Values	Limits as par IS 10500-2012 (Second revision)	
		Acceptable limit	Permissible limit
Physical Analysis			
pH value	7.33	6.5 to 8.5	6.5 to 8.5
Turbidity (NTU)	0.45	1	5
Total Dissolved Solids (mg/l)	142.00	500	2000
Total Hardness as CaCO ₃ (mg/l)	91.248	200	600
Chemical Analysis			
Iron (as Fe) mg/l	0.038	1.0	No Relaxation
Manganese(mg/L)	0.024	0.10	0.30
Residual Chlorine	-	0.2	1.0
Bacteriological Analysis			
Total Coliform Count (CFU/100ML)	0	0	0
E.coli Count (Faecal Coliform) (CFU/100ML)	0	0	0

*Above the permissible limit


Chemist


Paschim Barddhaman Water
Testing District Laboratory


Bacteriologist


Paschim Barddhaman water
Testine District Laboratory



Assistant Engineer -II
RCFA Div-I, Asansol
P.H.E.Dte.


Principal

Raniganj Lions J.D.M. Chanani
D.A.V. Public School


Manager

RLJDMC D.A.V Public School
RANIGANJ, WEST BENGAL