

# Asansol Municipal Corporation

## Borough-II, Raniganj

Md. Mozammil Hussain  
Chairman


N.S.B. Road, P. O:Raniganj  
Dist.: PaschimBardhaman.  
Pin: 713347

Phone : (0341)244-4825/244- 7485  
E-mail: ameraniganj@gmail.com

Ref. No. AMC-Rnj/Cert.24-25/ 339

Date : 01.10.2024.

### TO WHOM IT MAY CONCERN



It is certified that an inspection to Raniganj Lions J.D.M. Chanani DAV Public School, Lions Eye Hospital Road, Post-Raniganj, Dist. Paschim Bardhaman(W.B) was conducted by the Sanitary Department of Borough-II, Asansol Municipal Corporation recently and found that Raniganj Lions J.D.M. Chanani DAV Public School has proper hygienic sanitation condition in the School Building & the Campus.

*M. Hussain*  
01/10/24

Chairman, Borough-II,  
Asansol Municipal Corporation,  
Raniganj Office, Raniganj


Chairman, Borough - II  
Asansol Municipal Corporation  
Raniganj Office

# PASCHIM BARDHAMAN WATER TESTING DISTRICT LABORATORY

ISMILE (WEST), VIVEKANANDA PALLY, ASANSOL - 713301

Phone & Fax - 0341 2284210, E-mail:-ee\_rcfa\_d1@wbphed.gov.in,

Asansol PHE Office (R.C.F.A.Div-I) Laboratory, E-mail: rcfalabasansol@gmail.com  
Paschim Bardhaman,




## Results of Physical Chemical & Bacteriological analysis of water sample

Water sample of ----- RANIGANJ LIONS JDM CHANANI DAV PUBLIC SCHOOL  
(SENIOR SECONDARY ENGLISH MEDIUM SCHOOL)  
P.O-RANIGANJ, P.S-RANIGANJ, WEST BENGAL  
PASCHIM BARDHAMAN, PIN-713347


Sample received from----- FITER WATER  
Sample Collected by----- CONCERN AUTHORITY  
Sample received on ----- 04/12/2023  
Sample Tested on ----- 06/12/2023  
Sample reference no ----- 25/LAB-2023 /RCD-I

Parameters	Observed Values	Limits as par IS 10500-2012 (Second revision)	
		Acceptable limit	Permissible limit
<b>Physical Analysis</b>			
pH value	6.68	6.5 to 8.5	6.5 to 8.5
Turbidity (NTU)	2.18	1	5
Total Dissolved Solids (mg/l)	213.9	500	2000
Total Hardness as CaCO <sub>3</sub> ( mg/l )	111.24	200	600
<b>Chemical Analysis</b>			
Iron (as Fe) mg/l	0.18	0.30	1.0
Manganese(mg/L)	0.04	0.30	0.30
<b>Bacteriological Analysis</b>			
Total Coliform Count (CFU/100ML)	0	0	0
E.coli Count ( Faecal Coliform) (CFU/100ML)	0	0	0


\*Above the permissible limit


  
Chemist

Paschim Barddhaman Water  
Testing District Laboratory


  
Bacteriologist

Paschim Barddhaman water  
Testing District Laboratory

  
Assistant Engineer -II  
RCFA Div-I, Asansol  
P.H.E.Dte.

  
Principal

Raniganj Lions J. D. M. Chanani  
D. A. V. Public School

  
Manager 15.2.24

RLJDMC D.A.V Public School  
RANIGANJ, WEST BENGAL