

Asansol Municipal Corporation

Borough-II, Raniganj


Md. Mozammel Hussain
Chairman

N.S.B. Road, P. O:Raniganj
Dist.: PaschimBardhaman.
Pin: 713347

Phone : (0341)244-4825/244- 7485
E-mail: amcraniganj@gmail.com

Ref. No.: AMC-Rnj/N.O.C/25-26/ 372

Date : 15.09.2025.



TO WHOM IT MAY CONCERN

It is certified that an inspection to Raniganj Lions J.D.M. Chanani DAV Public School, Lions Eye Hospijjtal Road, Post & P.S. Raniganj, Dist. Paschim Bardhaman(W.B) was conducted by the Sanitary Department of Borough-II, Asansol Municipal Corporation and found that Raniganj Lions J.D.M. Chanani DAV Public School has proper hygienic sanitation condition in the School Building & the Campus.

Chairman,
Borough-II, Raniganj
Asansol Municipal Corporation
Chairman, Borough - II
Asansol Municipal Corporation
Raniganj Office

PASCHIM BARDHAMAN WATER TESTING DISTRICT LABORATORY

ISMILE (WEST), VIVEKANANDA PALLY, ASANSOL - 713301

Phone & Fax - 0341 2284210, E-mail:-ee rcfa dl@wbphed.gov.in,

Asansol PHE Office (R.C.F.A.Div-I) Laboratory, E-mail: rcfalabasansol@gmail.com

Paschim Bardhaman,




Results of Physical Chemical & Bacteriological analysis of water sample

Water sample of ----- RANIGANJ LIONS J.D.M CHANANI
DAV PUBLIC SCHOOL, RANIGANJ, PASCHIM BARDHAMAN.
Sample received from----- WATER SAMPLE OF PURIFIER
Sample Collected by----- CONCERN AUTHORITY
Sample Submitted by----- CONCERN AUTHORITY
Sample received on ----- 25/08/2025
Test Completion Date -----26/08/2025
Sample reference no ----- 38/1330/LAB-2025 /RCD-I
GRN NO:----- 192025260223702348
MEMO NO----- DAV RNJ/2025-26/530

Sample Tested as Received

Parameters	Observed Values	Limits as par IS 10500-2012 (Second revision)	
		Acceptable limit	Permissible limit
Physical Analysis			
pH value	7.33	6.5 to 8.5	6.5 to 8.5
Turbidity (NTU)	0.45	1	5
Total Dissolved Solids (mg/l)	142.00	500	2000
Total Hardness as CaCO ₃ (mg/l)	91.248	200	600
Chemical Analysis			
Iron (as Fe) mg/l	0.038	1.0	No Relaxation
Manganese(mg/L)	0.024	0.10	0.30
Residual Chlorine	-	0.2	1.0
Bacteriological Analysis			
Total Coliform Count (CFU/100ML)	0	0	0
E.coli Count (Faecal Coliform) (CFU/100ML)	0	0	0

**Above the permissible limit*


Chemist

Paschim Barddhaman Water
Testing District Laboratory


Bacteriologist

Paschim Barddhaman water
Testing District Laboratory


Assistant Engineer -II
RCFA Div-I, Asansol
P.H.E.Dte.