

Asansol Municipal Corporation At Raniganj

Vide notification no:- 335/MA/D/C-41/IM-36/2014 dated:- 03/06/2015

P. O.: Raniganj, Dist.: Burdwan. Pin: 713347

Phone: (0341) 244 4825, 244 7485 Fax: (0341) 244 1996

E-mail: raniganj_mu@yahoo.co.in Website: www.raniganjmunicipality.in

Ref No:- AMC-Rnj/Cert./20-21/

Date:- 23.02.2021.

TO WHOM IT MAY CONCERN

It is certified that an inspection to Raniganj Lions J.D.M. Chanani DAV Public School, Lions Eye Hospital Road, Post-Raniganj, Dist. Burdwan was conducted on behalf of Sanitary Department and Water Works Department of this administration recently and found that Raniganj Lions J.D.M. Chanani DAV Public School has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the School Building & the Campus as per the norms prescribed by the Central/State/U.T. Govt.

Member, Board of Administrator,
Asansol Municipal Corporation,
Raniganj Office, Raniganj
Member
Board of Administrators
Asansol Municipal Corporation

Principal
Raniganj Lions J.D.M. Chanani
D.A.V. Public School


Manager
Local Managing Committee
RLJDMC D.A.V Public School, Raniganj

PASCHIM BARDHAMAN WATER TESTING DISTRICT LABORATORY

ISMILE (WEST), VIVEKANANDA PALLY, ASANSOL - 713301

Phone & Fax - 0341 2284210, E-mail:-ee_rcfa_d1@wbphed.gov.in,

Asansol PHE Office (R.C.F.A.Div-I) Laboratory, E-mail: rcfalabasansol@gmail.com
Paschim Bardhaman,




Results of Physical Chemical & Bacteriological analysis of water sample

Water sample of ----- RANIGANJ LIONS JDM CHANANI DAV PUBLIC SCHOOL
(SENIOR SECONDARY ENGLISH MEDIUM SCHOOL)
P.O-RANIGANJ, P.S-RANIGANJ, WEST BENGAL
PASCHIM BARDHAMAN, PIN-713347


Sample received from----- FITER WATER
Sample Collected by----- CONCERN AUTHORITY
Sample received on ----- 04/12/2023
Sample Tested on ----- 06/12/2023
Sample reference no ----- 25/LAB-2023 /RCD-I

Parameters	Observed Values	Limits as par IS 10500-2012 (Second revision)	
		Acceptable limit	Permissible limit
Physical Analysis			
pH value	6.68	6.5 to 8.5	6.5 to 8.5
Turbidity (NTU)	2.18	1	5
Total Dissolved Solids (mg/l)	213.9	500	2000
Total Hardness as CaCO ₃ (mg/l)	111.24	200	600
Chemical Analysis			
Iron (as Fe) mg/l	0.18	0.30	1.0
Manganese(mg/L)	0.04	0.30	0.30
Bacteriological Analysis			
Total Coliform Count (CFU/100ML)	0	0	0
E.coli Count (Faecal Coliform) (CFU/100ML)	0	0	0


*Above the permissible limit



Chemist

Paschim Barddhaman Water
Testing District Laboratory



Bacteriologist

Paschim Barddhaman water
Testing District Laboratory


Assistant Engineer -II
RCFA Div-I, Asansol
P.H.E.Dte.


Principal

Raniganj Lions J. D. M. Chanani
D. A. V. Public School


Manager 15.2.24

RLJDMC D.A.V Public School
RANIGANJ, WEST BENGAL