

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 136/R/26-27

Dated: 30/07/2026

It is certified that an inspection team headed by **Lisha Roy, Quality Manager, AMBH LAB & team** from **Asansol mines Board of Health Lab** inspected the **Raniganj Lions JDM Chanani DAV Public School, Lions Eye Hospital Road, Raniganj – 713347, District- Paschim Bardhaman, West Bengal** on **24/07/2026** and on the basis of Water Test Report (Attached) bearing no. **AMBH/LAB/TR/261/2026** dated **30/07/2026** of **Asansol mines Board of Health Lab** certified that the **Raniganj Lions JDM Chanani DAV Public School** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **29/07/2027**.

Signature with Seal: *Lisha Roy*

Name: *LISHA ROY*

Designation: *Quality Manager*

Name & Address of the Office / Department:

Asansol Mines Board of Health Drinking Water
Testing Lab, DM Bungalow Compound,
Near Asansol Court, Asansol, Pin – 713304.



To

Raniganj Lions JDM Chanani DAV Public School

Lions Eye Hospital Road, Raniganj

Dist. – Paschim Bardhaman

Pin code – 713347

West Bengal

(Name & Address of the Institution)

Musey
Principal

Raniganj Lions J.D.M. Chanani
D.A.V. Public School

Harsh
Manager

RLJDMC D.A.V Public School
RANIGANJ, WEST BENGAL

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Asansol Mines Board of Health

Drinking water Testing Laboratory

Phone no- (0341) 225-2227 / 7001335214

Email- ambhlaboratory@gmail.com

Address- DM bungalow Compound, Near- Asansol Court, Asansol, Paschim Bardhaman, West Bengal - 713304

Format No - AMBH/LAB/FM/56

Name of the Client and Address	Report No	AMBH/LAB/TR/261/2026
Mondira Dey, Principal, Raiganj Lions J.D.M Chanani, D.A.V Public School, Raniganj	Report Issuing Date	30.07.2026
	Sample collected by	Party
	Sample type	Drinking Water
	Sample location	Tap From Location
	Sample received on	24.07.2026
	Sample condition	Sealed
	Period of Analysis	24.07.2026- 30.07.2026
Sample Returned / Stored	Stored at 4°C for one week from the date of report release.	

Test report

Sl no	Parameters	Unit	Limit as per IS 10500:2012	Test method	Results
1	Odour		unobjectionable	IS:3025 Part-05	unobjectionable
2.	Turbidity	NTU	5	IS:3025 Part-10	0.80
3.	pH @ 27°C		6.5-8.5	IS:3025 Part-11	7.05
4.	Total Dissolved Solid	mg/l	500	IS:3025 Part-16	208.00
5.	Total Hardness (as CaCO ₃)	mg/l	300	IS:3025 Part-21	122.40
6.	Total Alkalinity (as CaCO ₃)	mg/l	200	IS:3025 Part-23	85.53
7.	Chloride as Cl	mg/l	250	IS:3025 Part-32	10.76
8.	Nitrite Nitrogen (as NO ₂)	mg/l	0.10	IS:3025 Part-34	BDL
9.	Ammoniacal Nitrogen	mg/l	0.10	IS:3025 Part-34	BDL
10.	Calcium (as Ca)	mg/l	75	APHA 24 th Edition	32.70
11.	Magnesium (as Mg)	mg/l	30	APHA 24 th Edition	9.91

❖ BDL- Below Detection Limit

Chemically :- Satisfactory for Drinking Purpose.

AM

Analyst

Kroy

Authorised Signatory

Sr

HOD

Reviewed by

Quality Manager
AMBH LAB

HOD
AMBH LAB

Msey
Principal

Raniganj Lions J.D.M. Chanani
D.A.V. Public School

Manager

RLJDMC D.A.V Public School
RANIGANJ, WEST BENGAL



Asansol Mines Board of Health

Drinking water Testing Laboratory

Phone no- (0341) 225-2227 / 7001335214

Email- ambhlaboratory@gmail.com

Address- DM bungalow Compound, Near- Asansol Court, Asansol, Paschim Bardhaman, West Bengal - 713304

Format No - AMBH/LAB/FM/56

Report No

AMBH/LAB/TR/261/2026

Bacteriological Quality of Drinking water All water intended for Drinking

Sl No	Parameters	Requirements	Result
1	<i>E. Coli</i> or Thermo- tolerant Coliform Bacteria	Shall Not be detectable in any 100 ml sample	Not Detected
2	Total Coliform	Shall Not be detectable in any 100 ml sample	Not Detected

Remarks

Bacteriologically: - Satisfactory for Drinking Purpose.

Note: -

1. The sample is not drawn by us.
2. The above test values are reported as per the sample received.
3. Sample(s) will be disposed after 15 days from the date of issue of the report.
4. The test report shall not be reproduced without written permission from laboratory

Analyst

Reviewed by

Authorised Signatory

Quality Manager

HOD

HOD
AMBH LAB

Principal

Raniganj Lions J.D.M. Chanan
D.A.V. Public School

Manager

RLJDMC D.A.V Public School
RANIGANJ, WEST BENGAL